



Menlo Park Fire Protection District Fire Prevention Bureau

170 Middlefield Road

Menlo Park, CA 94025

Phone: (650) 688-8425 Fax: (650) 473-9847

www.menlofire.org

MENLO PARK FIRE PROTECTION DISTRICT DEMOLITION REQUIREMENTS

Water Supplies. An approved water supply for fire protection, either temporary or permanent, shall be made available as soon as combustible material arrives on the site. CFC 1412.1

Means of Egress. Required means of egress shall be maintained during construction and demolition, remodeling or alterations and additions to any building. CFC 1411.2

Stairways required. Where a building has been constructed to a height greater than 50 feet (15 240 mm) or four stories, or where an existing building exceeding 50 feet (15 240 mm) in height is altered, at least one temporary lighted stairway shall be provided unless one or more of the permanent stairways are erected as the construction progresses. CFC 1411.1

Operation of valves. Operation of sprinkler control valves shall be allowed only by properly authorized personnel and shall be accompanied by notification of duly designated parties. When the sprinkler protection is being regularly turned off and on to facilitate connection of newly completed segments, the sprinkler control valves shall be checked at the end of each work period to ascertain that protection is in service. CFC 1414.2

Emergency telephone. Readily accessible emergency telephone facilities shall be provided in an approved location at the construction site. The street address of the construction site and the emergency telephone number of the fire department shall be posted adjacent to the telephone. CFC 1409.1