



**Menlo Park Fire Protection District
Fire Prevention Bureau**

170 Middlefield Road
Menlo Park, CA 94025

Phone: (650) 688-8400 Fax: (650) 323-9129

**2010 CALIFORNIA RESIDENTIAL CODE
SMOKE AND CARBON MONOXIDE ALARM CERTIFICATION**

Smoke Alarms R314 – CA Residential Code Section 314

Smoke alarms shall be installed in the following locations:

1. In each sleeping room.
2. Outside each separate sleeping area in the immediate vicinity of the bedrooms. (i.e. Hallway)
3. On each story or level of the dwelling, including habitable basements and habitable attics.

Carbon Monoxide Alarms R315* - CA Residential Code Section 315

Carbon Monoxide Alarms shall be installed in the following locations:

1. Outside of each separate dwelling unit sleeping area in the immediate vicinity of the bedrooms. (i.e. Hallway)
2. On each story or level of a the dwelling, including habitable basements and habitable attics

*** Carbon Monoxide detectors are required when there are any fuel fired appliances and/or has an attached garage.**

I hereby certify that I have installed and tested, or have had an individual under my direction install and test all smoke alarms and carbon monoxide alarms for the address listed below. I further attest that all smoke alarms and carbon monoxide alarms are installed and working at the required locations.

Address: _____

Property Owner Name

OR

Contractor Name

Signature Owner or Contractor

Date

Phone Number